







**AS/NZS 3760: Australia and New Zealand Electrical Testing and Tagging Standards**

Your business is classified as a **category X** type of environment and/or equipment requiring 12 monthly testing.

Type of environment and/or equipment (a)	Class of equipment Class I, Class II, cord sets, cord extension sets and EPOD's (b)	Residual Current Devices (RCD's)			
		Push-button test – by user		Operating time and push button test	
		Portable (c)	Fixed (d)	Portable (e)	Fixed (f)
1. Factories, workshops, places of work or repair, manufacturing, assembly, maintenance or fabrication	6 months	Daily, or before every use, whichever is the longer.	6 months	12 months	12 months
<b>2. Environment where the equipment or supply flexible cord is subject to flexing in normal use OR is open to abuse OR is in hostile environment.</b>	<b>12 months</b>	<b>3 months</b>	<b>6 months</b>	<b>12 months</b>	<b>12 months</b>
3. Environment where the equipment or supply cord is <b>NOT</b> subject to flexing in normal use and is <b>NOT</b> subject to abuse and is <b>NOT</b> in a hostile environment.	5 years	3 months	6 months	2 years	2 years
4. Residential type areas of: hotels, residential institutions, motels, boarding houses, halls, hostels accommodation houses, and the like.	2 years	6 months	6 months	2 years	2 years
5. Equipment used for commercial cleaning.	6 months	Daily, or before every use, whichever is longer.	N/A	6 months	N/A
6. Hire Equipment Inspection Test and Tag	Prior to hire	Including push-button test by hirer prior to hire.		N/A	N/A
	3 months	N/A		3 months	12 months
7. Repaired, serviced and second-hand equipment.	After repair or service which could affect electrical safety, or on reintroduction to service, refer to AS/NZS 5762				